

Ref:CIVILAID:spl:4/1314 (j) Test Order dated: 17.04.2013

Date: 30.04.2013

M/s. United Office Systems Pvt. Ltd.,

Plot No. -62/1, 2 & 3, Vill-Vankas,

Taluka-Umbergoan, Dist. Valsad - 396150,

Gujarat, India

Attn.: Sri. Shabbir Rajkotwala

TEST REPORT ON ACCESS FLOORING SYSTEM

Source of sample

:

Customer's Reference Date of test

E mail letter dated 22.03.2013 15.04.2013

Tests Conducted

a. Concentrated Load Test till top deflection of

2.54mm, 3.00mm & 4.00 mm

Sample supplied by the customer

Sample Identification*

Steel Cementitious Panels with folded edge (bare)

Product Model No.*

"UNITILE UNIFOLD UFP 1000"

Product code No.* Panel size (Nominal) "UNITILE UFP 6400 1000 B 000 00 00000" 600 mm x 600 mm

Thickness / Gross weight of Panel

35 mm/15.200 kg. CISCA 2003-2004 -

Test Method

RECOMMENDED TEST PROCEDURE FOR ACCESS FLOOR.

TEST RESULTS

Concentrated Load Test at various Deflections

Sample reference	UNITILE UFP 35 1000(Corner Lock) 150 mm to 600 mm			
Finished floor height				
Location of indenter	Center	Edge	Corner**	
Deflection in mm at pre-load of 22.7kg	0.00			
Deflection in mm at load of 450 kg	1.65	1.52	2.18	
Residual deflection in mm at pre-load	0.06	0.03	0.10	
Location of indenter	Center E		dge Center	
Maximum Load at 2.54mm Deflection	484kg		489kg	
Maximum Load at 3.00mm Deflection	510kg		518kg	
Maximum Load at 4.00mm Deflection	555kg		560kg	

Note:

The panel is supported with 4 steel block jigs.

2. A new bare panel is used for each test. (Center, Edge, Corner **)

** Weakest point is located at about 220mm x 220mm from the corners.

contd...../-

Civil-Aid Technoclinic Pvt. Ltd. 1030, 13th Cross Banashankari 2nd Stage Bangalore - 560 070. India

Tel.: +91 80 39950500, 26716831

Fax: +91 80 26716833

ctccivilaidinfo.in@in.bureauveritas.com

Sr. Technical Officer

www.civilaid.com

Chennai (Off/Lab) Tel.: +91 44 24847345

Hyderabad (Off) Tel.: +91 40 66824582 Hyderabad (Lab) Tel.: +91 40 64584582

Mangalore (Off/Lab) Tel.: +91 824 2213571








PHOTO 1: Images of UNITILE UFP 35 1000 (Corner Lock) before Testing




PHOTO 2: Images of UNITILE UFP 35 1000 (Corner Lock) while Testing

* As furnished by the customer

Note: 1.The results relate only to the items tested.

2.Report shall not be reproduced, except in full without the written approval of the lab. 3.Any correction invalidates this report.

for CIVIL AID TECHNOCLINIC PVT. LTD.

RADHA KRISHNA

Sr. Technical Officer